

Series	Bravo												Elite						IOT				
	Basic PDU	Metered PDU	Monitor PDU	Switched PDU	POM	POM/KWH	SWH/KWH	MTH/KWH	POM Dual Input	Switched PDU w/o meter	Network ATS	Non-network ATS	POM/ KWH Adv.	POMO/ KWH Adv.	Switched/ KWH	Monitored/ KWH Adv.	Switched PDU w/o meter	Network ATS	ATS/POM/kWh Adv.	IOT			
Model Number Prefix	B1H/B1V/P BH/PBV	M1H/M1V	MTH/MTV, PTV	SWH/SWV PSV	MSH	WHH	WSH	WMH	P2H	NPS	ATS	STS	WHC/WHD/ PWC/PWD	WNC/WND/ PNC/PND	WSC/WSD/ PHC/PHD	WMC/WMD/ PEC/PED	NPD	ATD	APD	EM	TH	PM	IO
Features																							
Local Meter Display IP Address	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	Yes	Yes
Temp./Humidity Probe Connectivity	x	x	Yes *	x	Yes /1	Yes /1	Yes /1	Yes /1	Yes /1	x	Yes /1	x	Yes /2	Yes /2	Yes /1	Yes /2	Yes /1	Yes /2	Yes /2	Yes /2	Yes /2	Yes /2	Yes /2
Circuit Breaker Protection	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes *	Yes *	Yes	Yes	Yes	Yes	x	Yes *	Yes *	Yes *	x	x	x
Management Software	x	Free	Free	Free	Free	Free	Free	Free	Free	x	Free	x	Free	Free	Free	Free	Free	Free	Free	Free	Free	Free	Free
Redundant Power Protection	x	x	x	x	x	x	x	x	x	x	Yes	Yes	x	x	x	x	x	Yes	Yes	Yes	x	x	x
Information																							
Voltage (V)	x	x	x	x	x	Yes	Yes	Yes	x	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	Yes	x	Yes
Energy (kWh)	x	x	x	x	x	Yes	Yes	Yes	x	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	Yes	x
True RMS Current	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	Yes	x
Hz, PF, W, VA	x	x	x	x	x	Yes	Yes	Yes	x	x	x	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	Yes	x
Individual Outlet Current	x	x	x	x	Yes	Yes	Yes	x	x	Yes	x	x	Yes	Yes	x	x	x	x	Yes	Yes	x	x	x
Branch Circuit Circuit	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	x	x
Breaker Status Detection	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	x	x
Management																							
Outlet Control via Ethernet	x	x	x	Yes	Yes	Yes	Yes	x	Yes	Yes	x	x	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes	x	x
Outlet Group Control	x	x	x	Yes *	Yes	Yes	Yes	x	Yes		x	x	Yes	x	Yes	x	x	x	Yes	Yes	x	x	Yes
Schedule Control	x	x	x	Yes *	Yes	Yes	Yes	x	Yes	Yes	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	Yes	x	x
Ping NO Response Action	x	x	x	Yes *	Yes	Yes	Yes	x	Yes	Yes	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	x	x	Yes
User-Defined On/Off Sequence	x	x	x	Yes	Yes	Yes	Yes	x	Yes	Yes	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	x	x	Yes
Memorize Previous Outlet Status	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	Yes	x	x
Alternative Outlet Restart Mode	x	x	x	x	x	x	x	x	x	x	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	Yes	x	x
Outlet reacts automatically according to power events	x	x	x	x	x	x	x	x	x	x	x	x	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes	x	x
Alive of Heart Beat Trap Available	x	x	x	x	x	x	x	x	x	Yes	x	x	Yes	x	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes
Event Alert via Audible(Current, Temp./Humidity)	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Event Alert via Mail/Trap (Current, Temp./Humidity)	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
VoltageThreshold Configurable	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	x	Yes	x
Curret Threshold Configurable	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	Yes	x	Yes
Temp and Humidity Threshold Configurable	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Configuration																							
Ethernet	x	x	10M	10M	10M	10M	10M	10M	10M	10M	10M	x	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M	10/100M
User Account	x	x	1	1	1	1	1	1	1	1	1	x	8	8	8	8	8	8	8	8	8	8	8
SNMP	x	x	v1	v1	v1	v1	v1	v1	v1	v1	v1	x	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3	v1,v2,v3
DHCP/SMTP/NTP/UDP	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Telnet/ SSH communication in standard features	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Firmware Upgradable	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
SSLv3 TLS1.0 ,TLS1.1,TLS1.2	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Event and data logging in the PDU memory	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Three hierarchical access management	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
IP filter for web access security	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Radius Authentication	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Export and Import PDU Configuration	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Multi-languages support	x	x	x	x	x	x	x	x	x	x	x	x	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Physical																							
Outlet number (STD)	8/16/24/42	8/16/24/4	8/16/24/42	2/8/16/24	8	8	8	8	8	1/2/4	1/10	1/10	8/16/24/48	8/16/24/48	8/16/24/48	8/16/42	2	1/10	8	2	0	0	0
Outlet number (Tailored-made)	Yes	Yes	Yes	4/12	x	x	x	Yes	x	x	x	Yes	Yes	Yes	Yes	Yes	x	Yes	16	x	x	x	x
Voltage (V)	115/230/400	115/230/400	115/230/400	115/230/400	115/230	115/230	115/230	115/230	115/230	115/230	115/230	115/230	115/230/400	115/230/400	115/230/400	115/230/400	115/230	115/230	115/230	115/230	115/230	115/230	115/230
Capacity(Amp)	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16	15/16/30/32	15/16/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16/20/30/32	10/15/16	15/16/30/32	15/16/30/32	10/15/16	x	x	x
Display	x	LED	LED	LED	LED	LED	LED	LED	LED	x	LED	x	LED/OLED	LED/OLED	LED/OLED	LED/OLED	x	LED/OLED	LED/OLED	LED	LED	LED	LED
DIDO Support (Dry contact)	x	x	x	x	x	x	x	x	x	x	x	x	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional	x	x
Daisy Chain	x	x	x	x	x	x	x	x	x	x	x	x	Optional	Optional	Optional	Optional	Optional	x	x	x	x	x	x
*support model 30A and above																							

Model number Prefix for OLED Display			
WHL/WHK/ PWL/PWK	WNL/WNK/ PNL/PNK	WSL/WSK/ PHL/PHK	WML/WMK/ PEL/PEL
x	ATK	APK	